



ಭಾರತೀಯ ಜೀವ ವಿಮಾ ನಿಗಮ  
भारतीय जीवन बीमा निगम  
LIFE INSURANCE CORPORATION OF INDIA

Engineering Dept., Z.O. Unit,  
Dy. Chief Engineer's Office,  
"Jeevan Mangal" Bldg., Hayes Road  
BENGALURU - 560 025.

ಬೆಂಗಳೂರು - 560 025

e-mail: [bng.scz\\_engineering@licindia.com](mailto:bng.scz_engineering@licindia.com)

## **CORRIGENDUM - 1**

(including Clarifications to Pre-bid queries)

Name of work : e-Tender for **Proposed construction of BO bldg. incl.**

**Modernization at SRIRANGAPATNA** (under Mysuru divn.)  
(Tender no. 6)

Sl. No.	Reference of Tender clause no./ item no. page no., etc	Printed as	Read as	Remarks
1	BID- III, Part-I (Tender document), page no. 1	NAME OF WORK :: e-TENDER FOR PROPOSED CONSTRUCTION OF BRANCH OFFICE BUILDING INCLUDING MODERNIZATION WITH AC AT SRIRANGAPATNA UNDER MYSURU DIVISIONAL OFFICE, KARNATAKA STATE (Main Builder's work including Civil, Plumbing & Sanitary, Electrical, SITC of <u>Lift</u> , & other Ancillary works).	NAME OF WORK :: e-TENDER FOR PROPOSED CONSTRUCTION OF BRANCH OFFICE BUILDING INCLUDING MODERNIZATION WITH AC AT SRIRANGAPATNA UNDER MYSURU DIVISIONAL OFFICE, KARNATAKA STATE (Main Builder's work including Civil, Plumbing & Sanitary, Electrical, SITC of <u>Transformer</u> , & other Ancillary works).	
2	BID-III, Part-I (Tender document), page no. 280, Special Information & special conditions	The Contractor shall <b>co-operate in obtaining the Electric service connection</b> as required in preparation of as built drawings and working out the load calculations.	The Contractor shall obtain necessary " <b>Electrical Service connection</b> " as required from State Govt. Electricity authorities (like CHESCOM / KPTCL as applicable)/ Local authorities and other related offices including necessary liaison works & preparation of As- built drawings and working out the load calculations, Permission for road cutting from municipal authorities and connection, etc., before the building is handed over to the employer.	





**LIC**

ಭಾರತೀಯ ಜೀವ ವಿಮಾ ನಿಗಮ  
भारतीय जीवन बीमा निगम  
LIFE INSURANCE CORPORATION OF INDIA

Engineering Dept., Z.O. Unit,  
Dy. Chief Engineer's Office,  
"Jeevan Mangal" Bldg., Hayes Road  
BENGALURU - 560 025.

ಬೆಂಗಳೂರು - 560 025

e-mail: [bng.scz\\_engineering@licindia.com](mailto:bng.scz_engineering@licindia.com),

Sl. No.	Reference of Tender clause no./ item no. page no., etc	Printed as	Read as	Remarks
3	T.I. no. 1.01- Point Wiring, page no. 80	Wiring for light point /fan point/exhaust fan point/call bell point with 1.5 sq mm FR PVC insulated copper conductor single core cable in surface / recessed medium class FRLS conduit, with modular switch, modular plate, suitable G.I Box and earthing the point with 1.5 sq mm FRLS PVC insulated copper conductor single core cable etc as required. . Rate include cost of switch, plate etc and circuit wiring with 3x 2.5 sq mm FRLS wire in suitable medium gauge FR PVC conduit from DB to switch board/switch board to switch board.	Wiring for light point /fan point/exhaust fan point /call bell point with 1.5 sq mm Zero Halogen Flame retardant (ZHFR) PVC insulated copper conductor single core cable in surface / recessed Heavy duty (ISI marked) FRLS PVC conduit, with modular switch, modular plate, suitable G.I Box and earthing the point with 1.5 sq mm ZHFR PVC insulated copper conductor single core cable etc as required. . Rate include cost of switch, plate etc and circuit wiring with 3x 2.5 sq.mm ZHFR PVC insulated copper conductor wire in suitable Heavy duty (ISI marked) FRLS PVC conduit from DB to switch board/switch board to switch board.	
4	T.I. no. 1.02- Point Wiring, page no. 80	. Providing wiring for RAW Power outlet points with 3x1.5 sq mm 1100V PVC insulated FRLS multistrand copper wires in 20/25mm dia, medium duty FRLS conduit or PVC casing & capping with accessories run above false ceiling and partitions including supply & fixing 1 No. 6A, 5-pin universal socket modular with 1 No. 6A SP switch with indicator with Modular switch, socket, box accessories. etc. for the following. Maximum two circuits in each conduit from RAW Power DB. Rate to include for concealing the conduit /fixing on surface and switch box in wall with	Providing wiring for RAW Power outlet points with 3x1.5 sq mm 1100V PVC insulated ZHFR multistrand copper wires in 20/25mm dia, Heavy duty FRLS PVC conduit(ISI marked) or PVC casing & capping with accessories run above false ceiling and partitions including supply & fixing 1 No. 6A, 5-pin universal socket modular with 1 No. 6A SP switch with indicator with Modular switch, socket, box accessories. etc. for the following. Maximum two circuits in	



11/6/24  
EE(CC)

5

11/06/24  
DCE



**LIC**

ಭಾರತೀಯ ಜೀವ ವಿಮಾ ನಿಗಮ  
भारतीय जीवन बीमा निगम  
LIFE INSURANCE CORPORATION OF INDIA

Engineering Dept., Z.O. Unit,  
Dy. Chief Engineer's Office,  
"Jeevan Mangal" Bldg., Hayes Road  
BENGALURU - 560 025.

ಬೆಂಗಳೂರು - 560 025

e-mail: [bng.scz\\_engineering@licindia.com](mailto:bng.scz_engineering@licindia.com)

		necessary connections as directed. (For wall fan point switch to be provided at near switchboard or near 1.3 Meter height)	each conduit from RAW Power DB. Rate to include for concealing the conduit /fixing on surface and switch box in wall with necessary connections as directed. (For wall fan point switch to be provided at near switchboard or near 1.3 Meter height)	
Sl. No.	Reference of Tender clause no./ item no. page no., etc	Printed as	Read as	Remarks
5	T.I. No.1.04, 16/6A raw power outlet	16/6A raw power outlet : Supply & fixing Modular type 16/6A, 6-pin socket with 16A SP switch with indicator, box, plate for raw power including supply and providing wiring 3x4 sq mm 1100V PVC insulated FRLS multistrand copper wires in 20 / 25mm dia medium duty FRLS conduit including earthing and connections complete. (the wiring to the points is to be brought directly from one of the circuits of the D.B. provided in the floors)	16/6A raw power outlet : Supply & fixing Modular type 16/6A, 6-pin socket with 16A SP switch with indicator, box, plate for raw power including supply and providing wiring 3x4 sq mm 1100V PVC insulated ZHFR multistrand copper wires in 20 / 25mm dia heavy duty FRLS PVC conduit (ISI marked)including earthing and connections complete. (the wiring to the points is to be brought directly from one of the circuits of the D.B. provided in the floors)	

*[Signature]*  
EE 11/6/25

*[Signature]*  
EECC

*[Signature]*  
SE

*[Signature]*  
DCE 11/06/25







ಭಾರತೀಯ ಜೀವ ವಿಮಾ ನಿಗಮ  
भारतीय जीवन बीमा निगम  
LIFE INSURANCE CORPORATION OF INDIA

Engineering Dept., Z.O. Unit,  
Dy. Chief Engineer's Office,  
"Jeevan Mangal" Bldg., Hayes Road  
BENGALURU - 560 025.

ಬೆಂಗಳೂರು - 560 025  
e-mail: [bng.scz\\_engineering@licindia.com](mailto:bng.scz_engineering@licindia.com)

6	T.I. No.1.05, 16/6A raw power outlet	Providing wiring for UPS outlet points with FRLS 3x2.5 sq. mm PVC 110V copper conductor wires in 25mm dia, heavy duty FRLS PVC conduit or casing and capping with accessories run above false ceiling and partitions including supply and fixing 3 Nos. 6A, 5 pin universal socket with 1 No. 16A SP switch with indicator using MODULAR model for the following. Maximum two circuits in each conduit from UPS DB. Rate to include for concealing the conduit and Switch box in wall/panel Sockets with box to be provided below table and control switches above table as directed.	Providing wiring for UPS outlet points with ZRFR 3 x2.5 sq. mm PVC 1100V copper conductor wires in 25mm dia, heavy duty FRLS PVC conduit (ISI marked) or casing and capping with accessories run above false ceiling and partitions including supply and fixing 3 Nos. 6A, 5 pin universal socket with 1 No. 16A SP switch with indicator using MODULAR model, for the following. Maximum two circuits in each conduit from UPS DB. Rate to include for concealing the conduit and Switch box in wall/panel Sockets with box to be provided below table and control switches above table as directed.	
Sl. No.	Reference of Tender clause no./ item no. page no., etc	Printed as	Read as	Remarks
7	T.I. No.1.06	Providing wiring for UPS outlet points with 3x1.5 sq.mm PVC 1100V copper conductor FRLS wires in 20mm dia, heavy duty PVC FRL Sconduit or casing and capping with accessories run above false ceiling and partitions including supply and fixing 3 Nos. 6A 5 pin universal socket modular with 1 No. 16A SP switch with indicator with Modular switch socket box accessories etc. for the following. Maximum two circuits in each conduit from UPS DB. Rate to include for concealing the conduit and switch box in wall Sockets with box to be provided below table and control switches above table as directed.	Providing wiring for UPS outlet points with 3x1.5 sq.mm PVC 1100V copper conductor ZRFR wires in 20mm dia, heavy duty PVC FRLS conduit (ISI marked) or casing and capping with accessories run above false ceiling and partitions including supply and fixing 3 NOs. 6A, 5 pin universal socket modular with 1 No. 16A SP switch with indicator with Modular switch socket box accessories etc. for the following. Maximum two circuits in each conduit from UPS DB. Rate to include for concealing the conduit and switch box in wall Sockets with box to be	



Handwritten signatures and dates: 11/6/25, 11/6/25, 11/6/25



		Note: 1) The above points to be drawn from 1 <sup>st</sup> UPS SB of 2.5 sq.mm wire circuit. Max up to 3 extension can be given in work stations. 2) And can drawn directly from DB as directed.	provided below table and control switches above table as directed.	
		Note: 1) The above points to be drawn from 1 <sup>st</sup> UPS SB of 2.5 sq.mm wire circuit. Max up to 3 extension can be given in work stations. 2) And can drawn directly from DB as directed.		
Sl. No.	Reference of Tender clause no./ item no. page no., etc	Printed as	Read as	Remarks
8	T.I. No. 1.14	Supplying and fixing of following sizes of medium class FRLS PVC conduit along with accessories in surface/recess including cutting the wall and making good the same in case of recessed conduit as required	Supplying and fixing of following sizes of heavy duty FRLS PVC conduit (ISI marked) along with accessories in surface /recess including cutting the wall and making good the same in case of recessed conduit as required.	
9	T.I. No. 1.18	Supply and fixing of recessed mountable LED five (5) star rated luminaire size 595 X 595 (approx) full glow type with Min Lumen Output 3500 and lumen efficacy 90 lumen per watt on false ceiling complete including drivers etc. in all respects with necessary support from ceiling. The connection shall be made by providing 3 x 1.5 sq mm. Cu. Wires. Ref Model Philips. RC380B G2 LED35S or equivalent as approved.	Supply and fixing of recessed mountable LED luminaire size 595 x 595 (approx) full glow type with Min Lumen Output 3600 and minimum lumen efficacy 100 lumen per watt on false ceiling compete including drivers etc. in all respects with necessary support from ceiling. The connection shall be made by providing 3 x 1.5 sq. mm Cu. wires.	
10	T.I. No. 1.19	Supply, Installation, Testing and commissioning of Ultra modern recess / surface mountable 11 to 15 watt LED five (5) star rated down lighter fitting with lumen efficacy 120 lumen per watt including driver etc complete. The connection shall be made of providing 3 x 1.5 sq. mm.	Supply, installation, Testing and commissioning of Ultra modern recess / surface mountable 11 to 15 watt LED down lighter fitting with lumen efficacy 100 lumen per watt including driver etc. complete. The connection shall be made	



11/6/25

EE (C)

11/6/25

11/6/25





ಭಾರತೀಯ ಜೀವ ವಿಮಾ ನಿಗಮ  
भारतीय जीवन बीमा निगम  
LIFE INSURANCE CORPORATION OF INDIA

Engineering Dept., Z.O. Unit,  
Dy. Chief Engineer's Office,  
"Jeevan Mangal" Bldg., Hayes Road  
BENGALURU - 560 025.

ಬೆಂಗಳೂರು - 560 025

e-mail: [bng.scz\\_engineering@licindia.com](mailto:bng.scz_engineering@licindia.com),

Sl. No.	Reference of Tender clause no./ item no. page no., etc	Printed as	Read as	Remarks
		Copper wires. (Round / square / rectangle shape)	of providing 3 x 1.5 sq. mm. Copper wires. (Round / square / rectangle shape)	
11	T.I. No.1.20	Supply testing and commissioning of LED five (5) star rated 18 to 24 Wat 4 Feet surface / ceiling mounted Tube Light Fixture of minimum of 1800 Lumen output with necessary hardware, round block, and inter connection at either end and earthing complete etc as direct.	Supply, testing and commissioning of LED 18 to 24 Watt 4 Feet surface / ceiling mounted Tube Light Fixture of minimum of 100 Lumen per watt out put with necessary hardware, round block, and interconnection at either end and earthing complete etc. as directed.	
12	T.I. No. 21	Supply, testing and commissioning of LED five (5) star rated 10 Watt 2 Feet surface / ceiling mounted Tube Light Fixture for wash basin / mirror light of minimum of 1000Lumen out put per watt with necessary hardware, round block, and inter connection at either end and earthing etc complete as directed.	Supply, testing and commissioning of LED 10 Watt 2 Feet surface / ceiling mounted Tube Light Fixture for wash basin / mirror light of minimum of 100 Lumen per watt output with necessary hardware, round block, and interconnection at either end and earthing etc complete as directed.	
13	T.I. No. 23	Supplying and fixing of 450 mm sweep High Speed metal body wall mounted fan with pull cord as per manufacturer specification and standards.	Supplying and fixing of 450 mm sweep High Speed wall mounted fan with metal body and metal blade having non metallic capy with fire retardant material having melting point not less than 150 degree Centigrade along with thermal overload protection with pull cord as per manufacturer specification and standards.	



*[Signature]*  
4/6/25

*[Signature]*  
B. K. K. (C)

*[Signature]*  
Page 6 of 8

*[Signature]*  
Dec 11/06/25



**LIC**

ಭಾರತೀಯ ಜೀವ ವಿಮಾ ನಿಗಮ  
भारतीय जीवन बीमा निगम  
LIFE INSURANCE CORPORATION OF INDIA

Engineering Dept., Z.O. Unit,  
Dy. Chief Engineer's Office,  
"Jeevan Mangal " Bldg., Hayes Road  
BENGALURU - 560 025.

ಬೆಂಗಳೂರು - 560 025

e-mail: [bng.scz\\_engineering@licindia.com](mailto:bng.scz_engineering@licindia.com),

Sl. No.	Reference of Tender clause no./ item no. page no., etc	Printed as	Read as	Remarks
14	T.I. No. 24	Supply and fixing of 1 metre CAT-6, 4 pair patch mounting cord	Supply and fixing of 1 metre CAT-6 4 pair factory fabricated patch mounting cord	
15	T.I. No. 25	Supply and fixing of 2 metre CAT-6 4 pair patch mounting cord	Supply and fixing of 2 metre CAT-6 4 pair factory fabricated patch mounting cord	
16	Bid-II, Key dates, Pre bid queries by email, page no. 9	Up to 08.06.2025	Up to 08.06.2025	
17	Payment of EMD / Tender fees/ SD, any other fees, etc mentioned any where in the Tender document (Bid-I, Bid-II and Bid-III)	Demand draft /Banker's cheque shall be Payable at <b>Hyderabad</b>	Demand draft /Banker's cheque shall be Payable at <b>Bengaluru</b>	Including elsewhere mentioned in the Tender

11/6/25

EE(CC)

SE

11/06/25






ಭಾರತೀಯ ಜೀವ ವಿಮಾ ನಿಗಮ  
भारतीय जीवन बीमा निगम  
LIFE INSURANCE CORPORATION OF INDIA

Engineering Dept., Z.O. Unit,  
Dy. Chief Engineer's Office,  
"Jeevan Mangal " Bldg., Hayes Road  
BENGALURU - 560 025.  
ಬೆಂಗಳೂರು - 560 025  
e-mail: [bng.scz\\_engineering@licindia.com](mailto:bng.scz_engineering@licindia.com)


Sl. No	Tender Clause Reference	Tender Stipulations	Queries of Prospective Tenderers	LIC's Clarifications
18	LIST OF SPECIALISED WATER PROOFING AGENCIES, Page no. 187, Sl. No.76	There are six approved agencies under this category.	One of the prospective Tenderers requested to add some more agencies in this List of approved agencies under this category	No additions and the List of agencies mentioned in the Tender document remain same.


Date : 11.06.2025

  
**Dy. Chief Engineer**  
**L. I. C. OF INDIA**

Dy. Chief Engineer's Office  
Z.O. Unit, "Jeevan Mangal " Bldg.  
Hayes Road, BENGALURU - 560 025



 EE(L)

 11/6/25  
EG