

**Name of Work:- e-Tender for Supply, Installation, Testing and Commissioning of Solar Roof Top Systems for own buildings Under DO Vellore (Cluster-2) at (I) 20 Kwp at BO Neyveli (II) 20 Kwp at BO Villupuram. (III) 20 Kwp at BO Pondichery-1 (IV) 20 Kwp at BO Vridhachalam & (V) 20 Kwp at BO Chidambaram**

**Tender No:- LIC/SZ/ENGG/2025-26/ELEC/SOLAR/ CLUSTER-2**

**The Following Queries were raised by the bidders and Clarifications given is as under:-**

| Sl. No | Queries raised by Tenderer  | Clarifications given  |
|--------|---|---|
| 1.     | For AC armoured Cable – Whether the cable to be copper armoured or Aluminum armoured Cable.               | It is clarified that, It should be Copper Armoured Cable as mentioned in the tender.  |
| 2.     | Type of Electric power sanction from TANGEDCO .HT or LT   | It is clarified that, All Locations having LTCT or LT service connection only.  |
| 3.     | For Earthing – it will be Copper or GI Earth bit.   | It is clarified that, It should be Copper Earth bit as mentioned in the tender.   |
| 4.     | The 90 days schedule may be too early considering the timeline taken by TANGEDCO to Provide net Metering. | It is clarified that, It should be 90 days as per timelines mentioned in the tender.  |
| 5.     | Applying SIM card for Solar Monitoring System.  | It is clarified that, LIC Shall provide necessary documents for getting SIM card connection in the name of LIC. However follow-ups for getting connection and Recharging of SIM Card charges etc shall be as per tender conditions. |

**Date:- 16.09.2025**

**Chief Engineer**