

Annexure-A

Name of Work:- e-Tender for Supply, Installation, Testing and Commissioning Grid Interactive Roof Top Solar PV Systems Buildings Under DO Coimbatore DO-1 & DO-2 Chennai at (I) 20 Kwp at BO Pollachi-1 (II) 15 Kwp at BO Pollachi-2 (III) 20kwp at BO Kanchipuram (IV) 20 Kwp at BO Chengalpet & (V) 25 Kwp at BO Amabattur

Tender No:-LIC/SZ/Engg/2026-27/SOLAR/03

Pre-Bid Meeting Conducted on 20.08.2026 at 11.00Hrs

During the meeting the technical details of the tenderer were clarified and the queries raised by Tenderer are as under:

Sl. No	Queries raised by Tenderer	Compliance
1.	Solar PV Minimum Wattage	It is clarified that, the nominal power of a single PV Module shall not be less than 570 Wp as per technical bid.
2.	Using for GI Pipe – Eart pit	It is clarified that, GI Pipe to be used for road crossing only.
3.	Requirement of EB Bill for BO Pollachi BO-1 and BO Pollachi-2	EB bill send shortly through email
4.	General Discussion.	- Contractor should visit site before quoting the tender. - Contractor should visit EB Office for feasibility of net meter Connections. - Contractor should do follow-up with TNEB, CEIG etc to get net metering for completing the project in smooth manner.

Date:- 20.08.2026

Chief Engineer