

Tender for Modernization of DO Aligarh .(Reply to Pre-bid queries received over mail up to 1700 hours on 30.11.21).

No agency attended the Pre-bid meeting today, on 01.12.21.

Replies are as under:

SN	Queries raised by prospective bidders	LIC's Reply
01	EMD, tender fee should be accepted online and waiver of condition of submission of hard copy of tender with DD physically.	As per tender conditions.
02	Banker's Certificate is required to be addressed to Chief Engineer which entails certain cost. Hence it is requested to allow as " To whomsoever it may concern" or consider the one issued addressed to CE, EZO.	Each zone is a separate entity headed by an independent Chief Engineer. Hence action to be taken as per tender conditions.
03	Interior work: TI no. 1.04 : Full height 68mm thick double skin partition with 9mm tk fire resistant ply on both sides.....board...calcium silicate board.	Note no 01 on page 199 may be referred which says: P/f 68mm tk partition with 9mm tk double skin fire resistant ply conforming to IS 5509. Same is also clear in item description of TI 1.04. The word board, is to be read as, 9mm tk ply. Nowhere "calcium silicate" word is mentioned. Work to be carried out 68mm tk as per tender conditions.
04	TI 1.05: Low height partitions 68mm tk ...upto height of 1200mm...calcium silicate board?	-do- as above.
05	TI 1.06: P/f 68mm tk partly glazed....IS 5509... calcium silicate board	- do- as above.
06	TI 1.07 and 1.13: specification says " 6mm tk BWR ply ...IS 5509...TW frame...IS for BWR ply is IS-710...to use for this item	Note no 05 on page 199 may be referred which says: All plywood and block boards wherever mentioned shall be of 1st quality BWR ply/board fire resistant conforming to IS-5509/1659.
07	TI 1.12 says: P/f 68mm tk partly glazed..partition with 9mm tk fire resistant ply on both faces ... calcium silicate board?	Same as at 5 above.
08	TI 1.17 says: P/f BWR fire resistant ply conforming to IS 5509... specify grade of ply.	Same as at 06 above.

Contd Pg 02

		** 02 **
09	Solvency Certificate is to be addressed to whom? LIC Aligarh or Kanpur?	As per e-tender notice and Annexures, Annexure-I "BANKERS CERTIFICATE FROM A BANK", NOTE: 1." Banker's certificate should be on letter head of the Bank, addressed to Tender issuing Authority", which is Chief Engineer, LIC of India, Kanpur as per tender conditions.
10	As per tender NIT pre-bid meeting is on 01.12.21. Is it physical or online?	As per e-tender notice.
11	As per Annexure-III of e-tender notice regarding performance report, can we get it self-attested.. completion certificate of Govt sector?	Annexure-III, Performance Report has to be filled by the client and scanned copy is to be uploaded as per tender conditions.
12	Is pre-contract integrity pact required on Rs 100.00 stamp paper?	Pre-contract integrity pact is to be digitally signed and uploaded on plain paper alone.", as per tender conditions.

13. Please refer Pre-contract integrity pact page 28 para 7.1 line 7: The name and particulars of IEM Mr Chanderhasa Kata are to be treated as Deleted.